

**Notice to all Bidders.****RE: TENDER ADDENDUM 1**

RE: TENDER FOR CONSTRUCTION OF CIPU POLICE OFFICERS ACCOMMODATION AT GARSEN SUBSTATION, TENDER NUMBER KETRACO/PT/011/2024

The following amendments are made to the specified provisions of the **Tender For Construction of CIPU Police Officers Accommodation at Garsen Substation, Tender Number KETRACO/PT/011/2024 Under Section III**; Evaluation Criteria Clause 3.3. Save where expressly amended by the terms of this addendum, the Principal Tender Document shall continue to be in full force and effect.

Find herein the ADDENDUM, consisting of two (2) pages into the Principal Tender Documents.

Tender Addendum and clarification NO 1

| NO | EARLIER REQUIREMENT | CLARIFICATION |
|----|---|--|
| 1. | There was no requirement for;- 1. Height of the Water Tower: 2. Distance of Water Tank and Distance of Existing Water Supply: 3. The capacity of the septic tank and its distance of location from the buildings. 4. The tapping point of electricity for the houses and the approximate distance to the construction | <p>1. The height of the water tank tower shall be 9 metres high and shall be positioned approximately 120 metres from the proposed new structures.</p> <p>2. The distance to the nearest water point to the proposed housing unit is estimated to be 70 metres.</p> <p>3. The conventional septic tank design (size & capacity) shall be guided by the population it shall serve. The estimated population is estimated at 50 people/ persons.</p> <p>4. The electricity tapping point is estimated distance of 135 metres. A drop cable from KPLC side will be necessary including a meter box to serve new structures.</p> |

For any clarification, kindly email lswaleh@ketraco.co.ke ; nkandie@ketraco.co.ke: and
CC, pnjehia@ketraco.co.ke

The tender closing date has been extended to **30th April 2024 at 10:30 am. E A T.** All other terms and conditions of the tender remain the same.

USER REPRESENTATIVE: ENG. NICHOLAS KANDIE

DESIGNATION: SENIOR ENGINEER

SIGNATURE: 

PETER NJEHIA

SENIOR MANAGER, SUPPLY CHAIN

SIGNATURE: 

