



# CG Holdings Belgium NV

## Systems Division

Antwerpsesteenweg 167, B-2800 Mechelen

Tel.: +32(0)15/283 33 Fax: +32(0)15/283 491

www.cgglobal.com

Client: **Republic of Kenya – Ministry of Energy**

Project Name: **Nanyuki - Isiolo - Meru  
Electrification Project**

Contract Number: MOE-P4-2011


Document Title: **OHL 132 kV SINGLE SUSPENSION SET  
ASSEMBLY DRAWING**

Project Number: 100008  
Document Number: 100008-LO-DG-CA03  
Revision: 01

This document contains the following:

No.	Vendor Document number	Vendor Rev.	Description	Pages
1	13-0969	0	SINGLE SUSPENSION SET	1

01	21/05/2013	First issue	ARRUTI	NWLS	RCAV
Rev.	dd/mm/yyyy	Description	Created	Checked	Approved



BALL/SOCKET STANDARD COUPLING I6, IEC-I20

MINIMUM BREAKING STRENGTH OF STRING: 12.500 daN

CLAMP BREAKING LOAD: 12.000 daN

ARCHIVO: CAGOMM

7	I	ARMOUR RODS VPAL-I88-I99/D	I544	ALUMINIUM ALLOY		
6	I	SUSPENSION CLAMP GST-5	7736	ALUMINIUM ALLOY		
5	I	ARCING HORN 2xDC-35/II	8392	STEEL	GALVANIZED	
4	I	BALL SOCKET RC-I6-P/36	3863	STEEL	GALVANIZED	
3	I	ARCING HORN 2xDC-35/I9	82II	STEEL	GALVANIZED	
2	I	BALL EYE ABC-I6-P	3664	STEEL	GALVANIZED	
I	I	STRAIGHT SHACKLE GN-I6T	00I8	STEEL	GALVANIZED	
Qty		DESCRIPTION	REFERENCE	MATERIAL	FINISH	



DRAWN: X. ESPINOSA

SIGNATURE:

DO NOT SCALE

SINGLE SUSPENSION SET 132 KV  
FOR ACSR LYNX CONDUCTOR  
ASSEMBLY DRAWING

ISSUE	DATE
0	17-05-13
DRAW.	13-0969