



KAWI Complex • Block B  
Popo Lane, off Red Cross Road, South C  
P. O. Box 34942 – 00100, NAIROBI  
Phone: 020 4956000, 0719018000, 0732128000  
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

**ADDENDUM NO. 2**

**Our ref: KETRACO-PT-013-2025-2026**

**28TH APRIL 2026**

**NOTICE TO ALL BIDDERS**

**RE: PROCUREMENT OF AERIAL LIFT EQUIPMENT FOR TRANSMISSION  
LINE MAINTENANCE (TENDER NUMBER KETRACO-PT-0013-2025-2026)**

---

The following amendments are made to the specified provisions of the **PROCUREMENT OF AERIAL LIFT EQUIPMENT FOR TRANSMISSION LINE MAINTENANCE (TENDER NUMBER KETRACO-PT-013-2025-2026)**. Save where expressly amended by the terms of this addendum, the Principal Tender Document shall continue to be in full force and effect.

Find herein the ADDENDUM, consisting of three (3) pages into the Principal Tender Documents.

***Tender Addendum and clarification NO 2***

All other terms and conditions of the tender remain the same.

<b>Clause/No.</b>	<b>Statement in Document</b>	<b>Supplier clarification</b>	<b>Amendment</b>
Section 4.1 and GTP Clause 11.13	Maximum Working Outreach	<i>“Kindly confirm which value — <math>\geq 25</math> m as stated in Section 4.1 or <math>\geq 20</math> m as stated in GTP Clause 11.13 — represents the correct mandatory minimum working outreach requirement for this tender”</i>	i). Maximum working outreach $\geq 20$ m
Section 7 and GTP Clause 11.71.	Minimum Number of Operators for Training	<i>“Kindly confirm whether the minimum number of operators to be trained is 4 as stated in Section 7 or 3 as stated in GTP Clause 11.71.”</i>	ii). Minimum number of operators for training is four(4).
Section 8 and GTP Clause 11.75	Warranty period	<i>“Kindly confirm whether the correct warranty operating hours threshold is 2,000 hours as stated in Section 8 or 1,000 hours as stated in GTP Clause 11.75.”</i>	iii). Minimum warranty period is 12 months / 2000 hours whichever comes first.
Section 4.1 and GTP Clause 11.11	Maximum Working Height $\geq 50$ m	<i>“We sincerely appreciate the opportunity to participate in this tender. We request your consideration regarding the crane specification in the tender captioned. Currently, we can source cranes with a maximum reach of 38-meter.”</i>	Maximum Working Height $\geq 50$ m

Clause/No.	Statement in Document	Supplier clarification	Amendment
ITT 21.1	Completed tenders must be submitted on or before Date: <b>29<sup>th</sup> April 2026</b> Time: <b>10:30 AM EAT</b> Only Electronic Tenders will be permitted	N/A	Tender closing dates is extended to: Date: <b>5th May 2026</b> Time: <b>10:30 AM EAT</b> Only Electronic Tenders will be permitted



**SENIOR MANAGER, SUPPLY CHAIN**



**USER REPRESENTATIVE-SOPM**

Tender Addendum No. 2 of Tender No. **KETRACO-PT-013-2025-2026** has been received and incorporated in the Tender Documents.

**Name of Tenderer (in block letters):**

---

**Signature:**

---

**Date:**

---

**Signed for the Tenderer by (Name in block letters):**

---

**In the office bearer capacity of:**

---



---

