



KAWI Complex • Block B  
Popo Lane, off Red Cross Road, South C  
P. O. Box 34942 – 00100, NAIROBI  
Phone: 020 4956000, 0719018000, 0732128000  
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

Our ref: KETRACO/PT/028/2025-26

28TH MAY 2026

ADDENDUM NO. 2

NOTICE TO ALL BIDDERS

RE: TENDER FOR SUPPLY OF CLOSING AND TRIPPING COILS FOR CIRCUIT BREAKERS AND UNINTERRUPTIBLE POWER SUPPLY (UPS) (TENDER NUMBER KETRACO/PT/028/2025-26)

The following amendments are made to the specified provisions of the TENDER FOR SUPPLY OF CLOSING AND TRIPPING COILS FOR CIRCUIT BREAKERS AND UNINTERRUPTIBLE POWER SUPPLY (UPS) (TENDER NUMBER KETRACO/PT/028/2025-26). Save where expressly amended by the terms of this addendum, the Principal Tender Document shall continue to be in full force and effect. Find herein the ADDENDUM, AND CLARIFICATIONS consisting of two (2) pages into the Principal Tender Documents.

*Tender Addendum and Clarification No. 2*

NO	BIDDERS CLARIFICATION	KETRACOS RESPONSE
1.	Clarification if an external battery pack is required for the UPS Units. Based on the specifications a standalone UPS will not be able to meet the required backup time of >30 minutes at 70% load	Based on the UPS design, an external battery pack can be provided to meet the requirement
2.	Ketraco to provide Photos or Diagram of the Closing and Tripping coils	Photos of the closing and tripping coils attached

All other terms and conditions of the tender remain the same. Any tender inquiries should be sent to [kettenders@ketraco.co.ke](mailto:kettenders@ketraco.co.ke) to reach the Procuring Entity not later than seven days before the date of tender closing. The tender closing date is 5<sup>th</sup> June 2026 at 10.30 AM EAT.

**SENIOR MANAGER SUPPLY CHAIN**

Tender Addendum and Clarification No. 2 of Tender No. KETRACO/PT/028/2025-26 has been received and incorporated in the Tender Documents.


Name of Tenderer (*in block letters*): \_\_\_\_\_

Signature: \_\_\_\_\_



Date: \_\_\_\_\_



Signed for the Tenderer by (*Name in block letters*): \_\_\_\_\_

In the office bearer capacity of: \_\_\_\_\_



2. Trip coil images





1. Close coil images

