



KENYA ELECTRICITY TRANSMISSION CO.

Kawi Complex, Block B,
Popo Lane, Off Red Cross Road, South C
P. O. Box 34942 – 00100, NAIROBI
Phone: 020 4956000, 0719018000, 0732128000
Web: www.ketraco.co.ke • email: info@ketraco.co.ke

Our Ref: KETRACO/PT/006/2021

3rd March, 2021

Notice to all Bidders

RE: TENDER ADDENDUM AND CLARIFICATION 2

RE: CIRCUIT BREAKERS, ISOLATORS, SURGE ARRESTERS, CURRENT AND VOLTAGE TRANSFORMERS - KETRACO/PT/006/2021

The following amendments are made to the specified provisions of **Tender for Circuit Breakers, Isolators, Surge Arresters, Current and Voltage Transformers - KETRACO/PT/006/2021**. Save where expressly amended by the terms of this clarification, the Principal Tender Document shall continue to be in full force and effect.

Find herein the ADDENDUM and CLARIFICATION No. 2, consisting of ONE (1) page into the Principal Tender Documents. This document should be returned along with dully filled Form of Tender.

| No. | KETRACO Requirement Document (Page No.) | Clarification as requested by bidders | KETRACO Response |
|-----|---|--|---|
| 1 | | Reference to the subject tender, please advise the following: - - If this project is for a geothermal plant? - if for all rated voltage manufacturer has to consider technical features for presence of H ₂ S. Please also advise name of the substation where this equipment will be installed. | H ₂ S consideration shall be for 220kV disconnectors. These are spares. |

All other terms and conditions of the tender document remains the same.

PETER NJEHIA
SENIOR MANAGER, SUPPLY CHAIN