



KAWI Complex - Block B  
Popo Lane, off Red Cross Road, South C  
P. O. Box 34942 - 00100, NAIROBI  
Phone: 020 4956000, 0719018000, 0732128000  
Web: [www.ketraco.co.ke](http://www.ketraco.co.ke) - email: [info@ketraco.co.ke](mailto:info@ketraco.co.ke)

ADDENDUM NO. 1

Our ref: KETRACO-PT-013-2025-2026

17TH APRIL 2026

NOTICE TO ALL BIDDERS

RE: PROCUREMENT OF AERIAL LIFT EQUIPMENT FOR TRANSMISSION LINE  
MAINTENANCE (TENDER NUMBER KETRACO-PT-0013-2025-2026)

---

The following amendments are made to the specified provisions of the PROCUREMENT OF AERIAL LIFT EQUIPMENT FOR TRANSMISSION LINE MAINTENANCE (TENDER NUMBER KETRACO-PT-013-2025-2026). Save where expressly amended by the terms of this addendum, the Principal Tender Document shall continue to be in full force and effect.

Find herein the ADDENDUM, consisting of four (4) pages into the Principal Tender Documents.

*Tender Addendum and clarification NO 1*

All other terms and conditions of the tender remain the same.

No.	Statement in Document	Supplier clarification	Amendment
1	<p><i>“Electric“Electrical insulation of the platform is achieved through the boom structure (fiberglass/composite insulated sections), which serves as the primary dielectric barrier. The metallic cage forms an equipotential zone, ensuring uniform potential and enhancing operator safety in accordance with applicable international standards (ANSI/IEC).</i></p>	<p>Whether aerial platforms equipped with a non-insulated (steel) cage, but having a fully insulated boom system compliant with relevant standards, shall be considered acceptable.</p>	<p><i>This configuration shall be considered acceptable subject to strict compliance with the following conditions:</i></p> <p><i>The bidder/manufacturer shall provide documentary and certified evidence that the aerial platform, including the proposed working platform (cage), complies fully with the requirements of ANSI A92.2 and is specifically designed, tested, and certified for live-line operations up to 500 kV.</i></p> <p><i>The bidder shall further demonstrate that the overall system design—including the boom, platform, control systems, and insulation coordination—conforms to internationally recognized live-line working practices, ensuring effective control of leakage currents, equipotential conditions (where applicable), and maximum operator safety under all operating conditions.</i></p> <p><i>In addition: The bidder shall submit type test certificates, dielectric test reports, and compliance documentation supporting the proposed configuration.</i></p> <p><i>The Employer reserves the right to technically evaluate the suitability of the design for the intended live-line application.</i></p> <p><i>The bidder shall be required to</i></p>

			<i>conduct a live, physical demonstration of the equipment during training, clearly illustrating safe operation under live-line conditions and validating the proposed insulation concept.</i>
2	<i>"4.7.2 Provide OEM technical datasheets, catalogues, brochures and drawings for the aerial platform and all accessories"</i>	2. Item 4.7.2 - Provide OEM technical datasheets, catalogues, brochures and drawings for the aerial platform and all accessories. under the technical evaluation/requirements does not provide a submission/response box to allow responding in the Ariba SAP, please activate and correct accordingly.	Attach the requirement of 4.7.2( <i>Provide OEM technical datasheets, catalogues, brochures and drawings for the aerial platform and all accessories</i> ) as a combined attachment with requirement 4.7.5( <i>Provide manufacturer authorization Form (MAF)</i> ) within the provided submission/response box of Requirement 4.7.5 ( <i>Provide manufacturer authorization Form (MAF)</i> )
3	Completed tenders must be submitted on or before <b>22<sup>nd</sup> April 2026 10:30 AM</b> Only Electronic Tenders will be permitted	we respectfully request an extension of the tender closing date to allow sufficient time for stabilization of supplier pricing and submission of a responsive and compliant bid.	Tender closing dates is extended to: Date: <b>29th April 2026</b> Time: <b>10:30 AM EAT</b> Only Electronic Tenders will be permitted



**SENIOR MANAGER, SUPPLY CHAIN**



**USER REPRESENTATIVE-SOPM**

Tender Addendum No. 1 of Tender No. KETRACO-PT-013-2025-2026 has been received and incorporated in the Tender Documents.

Name of Tenderer (*in block letters*): \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Signed for the Tenderer by  
*(Name in block letters):*  
In the office bearer  
capacity of:

---

---

---