

Our Ref: KETRACO-PT-034-2024


29th October, 2024

Notice to all Bidders

RE: TENDER ADDENDUM AND CLARIFICATION 1 FOR SUPPLY OF SPARES FOR SUBSTATIONS: SILICA GEL FOR TRANSFORMER BREATHERS, SF6 GAS WITH CYLINDERS AND LIFTING SLING ROPES (KETRACO-PT-034-2024)

The following amendments are made to the specified provisions of **Tender For Supply Of Spares For Substations: Silica Gel For Transformer Breathers, Sf6 Gas With Cylinders And Lifting Sling Ropes (KETRACO-PT-034-2024)**. Save where expressly amended by the terms of this clarification, the Principal Tender Document shall continue to be in full force and effect.

Find herein a ADDENDUM AND CLARIFICATION No. 1, consisting of three (3) pages into the Principal Tender Documents as attached. This document should be returned along with dully filled Form of Tender.

No	Clause	Clarification	KETRACO Response
1	Tender Description	Tender For Supply Of Spares For Substations: Silica Gel For Transformer Breathers, Sf6 Gas With Cylinders And Lifting Sling Ropes (KETRACO-PT-034-2024)	Tender For Supply Of Spares For Substations: Silica Gel For Transformer Breathers, Sf6 Gas With Cylinders And Lifting Sling Ropes (KETRACO-PT-034-2024)
2	Schedule of requirements	With regards to double sling does that mean it is a duplex sling or a 2-legged sling?	It is a duplex sling
3	Technical Specification for Lifting Sling Rope	Extra strong PU-impregnated webbing of the sleeve can we have more information on this requirement.	Polyurethane (PU) resin impregnation process should be used in the manufacturing process to ensure the slings are impervious to entry of dirt
4	Technical Specification for Lifting Sling Rope	If it is possible for you to send us a picture of the sling required it would be much appreciated so we can quote accordingly	
4	Technical Specification for Lifting Sling Rope	Just to confirm on all the tonnages the length required is 10mtrs	Yes. Length for all tonnages is 10m
5	Clause 5 (Requirements) of Specifications for silica gel for	The manufacturer of the silica gel wants a clarification on what you mean by airtight synthetic material container?	Storage used should be airtight , the storage material notwithstanding. The type of storage should be detailed and provided with the bid.

	transformer breathers (parking and marking)		The material should be airtight to prevent moisture ingress.
6	Clause 8 of specifications for SF6 Gas with Cylinders	General Clarification	There shall be physical Factory Acceptance Testing (FAT) at the manufacturer's premises, as per the IEC 60376 and other relevant IEC standards. KETRACO Engineers shall witness the testing before dispatch of the SF6 gas with cylinders. The team will also inspect the cylinders to ensure packaging and labelling is as per specifications. The tenderer shall inform KETRACO at least one month in advance of the FAT date and submit the test protocol for approval. Tenderers shall give separate costs for FAT at the factory for a maximum of two engineers. This cost shall cover visa fees, flight tickets, accommodation, food, local transport, and a daily 200 USD stipend for each of the client engineers for the total duration of the FAT.

All other terms and conditions of the tender document remains the same.

USER REPRESENTATIVE: REAGAN OLOKA

SIGNATURE:

Reagan

APPROVED BY:

Hesbon

HESBON KISERO

Ag. SENIOR MANAGER, SUPPLY CHAIN

Tender Addendum and Clarification No. 1 of Tender No. **KETRACO-PT-034-2024** has been received and incorporated in the Tender Documents.

Name of Tenderer (*in block letters*):

Signature:

Date:

**Signed for the Tenderer by
(*Name in block letters*):**

**In the office bearer
capacity of:**

