

Our Ref: KETRACO/PT/018/2023

15th June, 2023

Notice to all Bidders

RE: TENDER ADDENDUM AND CLARIFICATION 3

RE: RESTORATION OF COLLAPSED TOWERS ON LOIYANGALANI – SUSWA TRANSMISSION LINE - KETRACO/PT/018/2023

The following amendments are made to the specified provisions of **Tender for Restoration of Collapsed Towers on Loiyangalani – Suswa Transmission Line - KETRACO/PT/018/2023**. Save where expressly amended by the terms of this clarification, the Principal Tender Document shall continue to be in full force and effect.

Find herein the ADDENDUM and CLARIFICATION No. 1, consisting of EIGHTEEN (18) pages into the Principal Tender Documents as attached. This document should be returned along with dully filled Form of Tender.


The following were clarifications sought;

No.	Clarification as requested by bidders	KETRACO Response
1	The following forms are missing from the documents and there are specific attachments assigned. Please upload them for execution from our end. 3.2.11 – Qualification form 3.2.14.2 – Conflict of Interest 3.2.14.3 – Eligibility PPRA 3.2.14.4 – State Owned Entity 3.2.14.5 – Origin of Good from Eligible Countries 3.2.14.6 – Not Debarred Declaration 3.2.14.10 – ESHS Declaration 3.3.5 – Professional Qualifications	The following forms that were missing from the document are hereby attached; 3.2.11 – Qualification form 3.2.14.2 – Conflict of Interest 3.2.14.3 – Eligibility PPRA 3.2.14.4 – State Owned Entity 3.2.14.5 – Origin of Good from Eligible Countries 3.2.14.6 – Not Debarred Declaration 3.2.14.10 – ESHS Declaration 3.3.5 – Professional Qualifications
2	As per our understanding during the site visit, there are 5 new towers required whereas the BOQ in Amendment 2 states 6 towers. Kindly confirm whether it is 5 or 6.	Contract to quote for five(5) Towers. NSK-3 Towers LAK-1 Tower MAK-1 Tower Amended price schedule attached.
3	Please also confirm whether the old towers were HSK or NSK types and also HAK or MAK types.	The previous collapsed Towers were classified as follows; NSK-4 Towers MAK-1 Tower

Handwritten signature and date 14/6

4	Due Diligence(Previous Undertaken projects)	<p>The employer shall carry out a due diligence of the projects previously undertaken by the qualified bidder of the Tender before the contract is awarded.</p> <p>The cost of the due diligence based on government rates shall be included in the bid document.</p>
5	Tender closing date	Tender closing date remains the same.

All other terms and conditions of the tender document remains the same.



PETER NJEHIA
SENIOR MANAGER, SUPPLY CHAIN

