

**SCHEDULE OF REQUIREMENTS FOR PROCUREMENT OF AIR
CONDITIONING UNITS AND ACCESSORIES FOR INSTALLATION IN
KETRACO SUBSTATIONS**

Item Description	Quantity	Delivery time	Unit cost	Total Cost plus 16% V.A.T
Single phase, energy saving, spliter type air conditioning unit 28,000 BTU/H, R410A	14			
Single phase, energy saving, spliter type air conditioning unit 24,000 BTU/H, R410A	24			
Single phase, energy saving, spliter type air conditioning unit 18,000 BTU/H, R410A	11			
2.5mm, four core, power and communications black flexible cable, 90m roll	3			
(5/8) inch high-quality air-conditioning copper pipe, 15m roll	4			
(1/2) inch high-quality air-conditioning copper pipe, 15m roll	8			
(3/8) inch high-quality air-conditioning copper pipe roll, 15m roll	4			
(1/4) inch high-quality air-conditioning copper pipe, 15m roll	8			
Armflex rubber insulation for 5/8-inch copper pipe, 1.9 m long string	30			
Armflex rubber insulation for 1/2 inch copper pipe, 1.9 m long string	60			
Armflex rubber insulation for 3/8-inch copper pipe, 1.9 m long string	30			
Armflex rubber insulation for 1/4 inch copper pipe, 1.9 m long string	60			
20mm heavy gauge black PVC pipe ,3m	55			
1/2 inch heavy gauge black elbows	55			
Tangit glue 500g	10			
White A/C PVC non glue insulation tape 10mmX5mm	40			
Grey 1 inch wall plugs packet	5			
Grey 1/2-inch wall plugs packet	20			
1-inch self-tapping screws packet	5			
1/2 inch self-tapping screws packet	20			

Name of tenderer:

Signature of tenderer:

Date :

No.	Request for information from bidder	Clarification by KETRACO
1.	<p>In your Request for Proposal, you have mentioned the need for an air conditioner, but there is no specification on the type of air conditioner required. Therefore, I would like to request further information about the type of air conditioner you prefer.</p> <p>- wall-mounted, ducted, or ceiling cassette.</p>	<p>We are interested in procurement of both AC units and the related consumables. The Air conditioning units of interest are the splitter type or what you referred to as wall mounted. We are only interested in supply of the units and their consumables, installation and sizing by HVAC contractors isn't part of the scope of works.</p>
2.	<p>Confirm which type amongst the below do you wish to procure.</p> <ol style="list-style-type: none"> 1. Wall mounted 2. Ceiling Cassette 3. Ductile - Sealing conceal 4. Convertibl 	<p>Splitter type is wall mounted.</p>
3.	<p>For the 28,000 BTU item. The standards are 12, 18, 24 & 36. Kindly clarify is the requirement is for 36,000 BTU as 28,000 BTU doesn't exist.</p>	<p>Kindly note that the Single phase, energy saving (inverter tech), splitter type air conditioning unit 28,000 BTU/H, R410A are available in the market.</p>
4.	<p>The schedule of requirement is not clear</p>	<p>Please find attached the schedule of requirements as part of this addendum.</p>
5.	<p>We are also requesting for extension of closing date to allow for more time to source.</p>	<p>Please note that the closing date has been extended to 8th March 2023 at 10.00am Local time.</p>

