



- 1- THIS DRAWING IS FOR BIDDING PURPOSE ONLY
- 2- ALL RELAYS SHALL SUPPORT IEC-61850 PROTOCOL.
- 3- ALL RELAYS PHYSICAL LINK SHALL FOLLOW THE EXISTING SCHEME.

* THE BURDEN OF CTs AND CVTs SHALL BE FINALIZED AT DETAIL DESIGN STAGE BY EPC CONTRACTOR, SUBJECT TO APPROVAL OF BURDEN CALCULATIONS BY CLIENT/CONSULTANT.

8