

## INTERIOR FINISHING SCHEDULE

ROOM NO.	ROOM NAME	FLOOR	SKIRTING	WALL
G1	FIRE WATER PUMP HOUSE	EPOXY PAINT ON CONC.SLAB	CERAMIC TILE (H= 100 mm)	CEMENT PLASTER WITH WHITE FLAT EMULSION PAINT

*NOTE:*

- 1- THE ROOF SHALL BE COVERED WITH Min. 60 MM Thick. ROOF SANDWICH PANEL.
- 2- THE GUTTER AND GUTTER STRAP DETAILS SHALL BE PROVIDED BY CONTRACTOR DURING EPC DETAIL DESIGN STAGE.  
WITH THE RELEVANT CALCULATION AS PER RAINFALL LEVEL AND WATER FLOW VALUE, SUBJECT TO CLIENT/CONSULTANT APPROVAL.
- 3- ALL EXTERNAL DOORS SHALL BE MADE OF 1.5MM MIN THICKNESS ZINC-COATED STEEL SHEET WITH A PANIC LOCK.  
+ALL DOOR SHALL BE FIRE RESISTANCE.  
+ALL WINDOWS ARE DOUBLE GLAZED WITH HEAVY DUTY ANODIZED ALUMINUM FRAMES.
- 4- ALL BUILDING SHALL BE PAINTED WITH KETRACO APPROVED CLOURS.
- 5- ALL BUILDING EXTERNAL WALL FINISHING SHALL BE CEMENT PLASTER WITH WHITE FLAT EMULSION.
- 6- ULTIMATELY, THE FINAL DOOR AND WINDOW SIZES AND DESIGN SHALL BE SUBJECT TO APPROVAL BY THE EMPLOYER'S REPRESENTATIVE.

[illegible]