



KENYA ELECTRICITY TRANSMISSION  
CO.

Kawi Complex, Block B, Popo  
Lane, Off Red Cross Road, South  
C P. O. Box 34942 – 00100,  
NAIROBI Phone: 020 4956000,  
0719018000, 0732128000.

Web: [www.ketraco.co.ke](http://www.ketraco.co.ke)

Email: [info@ketraco.co.ke](mailto:info@ketraco.co.ke)

Our Ref: KETRACO-PT-022-2025

12<sup>th</sup> May 2025

Notice to all Bidders

**RE: TENDER ADDENDUM AND CLARIFICATION 1 FOR REINSULATING OF BROKEN  
INSULATOR DISCS ON 500KV ETHIOPIA-KENYA TRANSMISSION LINE**

The following amendments are made to the specified provisions of Reinsulating of Broken Insulator Discs On 500kv Ethiopia-Kenya Transmission Line (**KETRACO-PT-022-2025**). Save where expressly amended by the terms of this clarification, the Principal Tender Document shall continue to be in full force and effect.

Find herein an ADDENDUM AND CLARIFICATION No. 1. This document should be returned along with the duly filled Form of Tender.

No	Clarification	KETRACO Response
1.	The Site Visits scheduled for the 13th to 16th as per the TDS - ITT 7.2 - are Mandatory and will cover 4 days.	Site visit is mandatory and will take place on 14 <sup>th</sup> May, 2025 Time: 10:00 AM Place of converging: Archers post Samburu The contact person is Eng. Kennedy Ouma (Tel 0722989955)
2.	Kindly confirm if the above works will be undertaken under live line or offline cold line conditions.	The works will be undertaken under cold line conditions.

All other terms and conditions of the tender document remain the same.

USER REPRESENTATIVE: Francis Mutinda

SIGNATURE: \_\_\_\_\_

APPROVED BY:

  
Ag. SENIOR MANAGER, SUPPLY CHAIN

Tender Addendum and Clarification No. 1 of Tender No. KETRACO-PT-022-2025 has been received and incorporated in the Tender Documents.

Name of Tenderer *(in block letters)*:

---

Signature:

---

Date:

---

Signed for the Tenderer by  
*(Name in block letters)*:

---

In the office bearer capacity  
of:

---

---